



GOVERNMENT OF TELANGANA
REGIONAL PUBLIC HEALTH LABORATORY, WARANGAL
 HANAMKONDA (KUDA Premises) - 506 001.
Report of Physical, Chemical Analysis of Water &
Chemical Analysis of Water for Construction Purpose*

Sample from : The Principal, Paramita Heritage School,

Collected by : Selb Padmanagar,

Paid / Free :

Collected on : 18/12/2025 Dist - Karimnagar

Receipt No. : 7838

Received on : 19/12/2025

Amount : 230.00

Lab Ref. No. :		428		IS10500:2012	
Address of Sources :		R.O. plant under d- School		Acceptable limit	Permissible limits in the absence of alternate source
Substance or Characteristic :					
Colour :		15		5	15
Odour :		Agreeable		Agreeable	Agreeable
Turbidity NTU :		-		1	5
*P ^H at °C :		6.8		6.5 - 8.5	No relaxation
Electrical conductivity (at 25° C Micro Mhos /cm) :		78			
* Total Dissolved Solids (mg/Lt.) :		50		500	2000
The following results are in mg/liter					
Phenolphthalein Alkalinity :		NIL			
Total Alkalinity (as CaCO ₃) :		15		200	600
Total hardness (as CaCO ₃) :		5		200	600
Calcium hardness (as CaCO ₃) :		4			
Magnesium hardness (as CaCO ₃) :		1			
Sulphate (as SO ₄ ²⁻) :		-		200	400
Nitrite (as NO ₂) :		NIL			
Nitrate (as NO ₃) :		-		10	No relaxation
*Chloride (as Cl) :		18		250	1000
Fluoride (as F) :		0.02		1.0	1.5
Iron (as Fe) :		-		0.3	No relaxation
*To neutralize 100 ml of water sample using phenolphthalein indicator with 0.02N Na OH (in ml) :				Not more than 5 ml as per is 456 (2000) (Reaffirmed 2005)	
*To neutralize 100 ml of water sample using Mixed indicator with 0.02N H ₂ SO ₄ (in ml) :				Not more than 25 ml as per is 456 (2000) (Reaffirmed 2005)	

The Given Water Sample is physico-chemically
Satisfactory for Drinking purpose.

S. S. Sankar
 Senior Analyst

M. V. V. V. V.
 Civil Surgeon Bacteriologist I/C

P. S. Sankar
 25.1.25

PRINCIPAL
Paramita Heritage School
 Affiliated to the CBSE # 3630258
 Padmanagar, Karimnagar

T. S. Sankar
Secretary & Correspondent
Aravinda Educational Society
Karimnagar

